



Public Works Report April 24-May 5 2017

- Cleaned up fire pits that were made on the beach
- Looked at 2017 drainage plan with South Shore Bobcat
- Regular water samples
- Spoke to J.P. Mills about all the samples and where to pull them from
- Located manhole in field too see if sample could be pulled from there. ... could not
- Cleaned up ball diamonds, moved the tables, fencing and poles
- Meter Read Edgewood
- Meter read Village
- Put up Tower Rd sign
- Replaced speed bump sign @ Shady and Grand ave
- Put up clean up after your dog sign
- Put up no motor vehicle signs @ ball diamonds and Dobson park
- City run for chlorine
- Graded McNab Rd , dump rd, Highwood ave – Hillside, Hillside , 10th st, Lakeview cres
- Graveled Highwood to Hillside rd, Hillside Rd , Lakeview (from Park Place – Hillside), booster station
- Filled in giant hole in front of 1360 Highwood
- Amped Electric returned to install proper switch

- Pulled 18 samples from Raw supply line and Distributed line for Stantec
- Took samples into Lab
- o Water turn on's X 38



Public Works Report May 8-May 19 2017

Located curbstop on Hillside work order #22

Checked meter @111 Hillside place needs new meter work order #

Checked meter @ 1151 Shady Lane needs new meter work order #84

Took hoses and pump to Gary La Montagne work order #81

Turned beach bathroom on work order #82

Filled pots with soil for parks and rec #79

Erected small snow fence @ ball diamonds around poles and fencing

Checked on several items for budget

Fixed driveway @ 161 Woodland ave (located curbstop in winter)

Fixed dip @ Woodland and 16th

Dump run (Ball diamond garbage)

Gave John Deere look over for summer (coolant, oil, air filter, tire pressure etc.) Changed oil

Issues with Email @ shop

Put out all the garbage bins @ beach, cleaned out beach bathroom

Mowed ball diamonds, ditch , tree line

Mowed Edgewood

Turned sprinklers on @ Edgewood, changed out valves

Flushed Village (two days)

Issues @ the booster station with pumps, report from Iles Electric to come

Curbside leak / repair @ 357 Grand Ave done by South Shore Bobcat

Turn ons X 25

Filling in gopher holes @ ball diamonds and well