## PUBLIC WORK'S REPORT

Report prepared for Nov 28th council meeting



## Report for Mar 12 - Mar 23, 2018

## Mar 12 - March 23, 2018

- Snow Removal
- Remove sander, Haul Snow to Shop
- Water Meters, Cell Auto Reads
- Clean Culverts
- Rescue Bobcat
- Monday March 19 found small leak in water tower, later that morning an anode was tore off wall and 3 more larger leaks appeared. Lowered water level, and took tower offline.
- Tuesday March 20, report a water break, service connection line at 201 Woodland Ave.
- Wednesday repair leak back fill dig.
- Weld patches on all anode bolts as per instructions of Municipal Utilities. Send invoices to them.
- Sander back on to FL-70
- Bobcat back from repair